

## **SECTION 338120 - STONE AGGREGATE PAVING**

### **PART 1 - GENERAL**

- 1.1 Description of Work: Provide stone aggregate paving, complete in place.
- 1.2 Weather Conditions: Place stone aggregate paving only when subgrade is free of water or mud and air temperature is 40 degrees F., or higher.
- 1.3 Grade Control: Establish and maintain required alignment and grades, including crown and cross slope.

### **PART 2 - PRODUCTS**

- 2.1 Stone Aggregate Paving: Crusher run stone, acceptable to the A-E, obtained from local commercial quarries.

### **PART 3 - EXECUTION**

- 3.1 Place stone to the compacted depth shown on the drawings. Compaction of stone shall be in accordance with NCDOT "Standard Specifications for Roads and Structures," Section 520.

**END OF SECTION 338120**