



SECTION B-B

NOTES:

- 1) COMMERCIAL DRIVEWAYS SHALL BE AT A MINIMUM, IN ACCORDANCE WITH THE LATEST EDITION OF THE "POLICY ON STREET AND DRIVEWAY ACCESS TO NORTH CAROLINA HIGHWAYS", PUBLISHED BY THE NORTH CAROLINA DEPARTMENT OF TRANSPORTATION, TRAFFIC ENGINEERING BRANCH. RESIDENTIAL DRIVEWAYS SHALL BE IN ACCORDANCE WITH CHAPTER 24, ARTICAL 111 OF THE CITY CODE.
- 2) ALL CONCRETE SHALL BE 6" DEEP, MINIMUM.
- 3) MINIMUM RADIUS- 2' RESIDENTIAL, 5' COMMERCIAL.
- 4) THE DRIVEWAY RAMP MUST RISE 4 INCHES ABOVE THE FLOW LINE OF THE GUTTER AT A POINT NO CLOSER THAN TWO FEET FROM THE GUTTER.

CITY OF SALISBURY, N.C. STANDARD DETAIL

DATE: JANUARY 1, 1991

ROADS

NOT TO SCALE

DRIVEWAY RAMPS VERTICAL C&G

STANDARD

R-10