



- ① RETAINER GLAND (MEGA-LUGS) FOR DUCTILE IRON PIPE. PROVIDE RETAINER GLAND FOR EACH MECHANICAL JOINT FITTING (TEE, VALVE, BEND)
- ② M.J. PLUG WITH THREADED HOLE FOR 2" BLOW-OFF PIPE OR M.J. REDUCER FOR BLOW-OFFS LARGER THAN 2".
- ③ END OF LINE PIPE MATERIAL SHALL BE DIP.
- ④ BLOW-OFF REQUIRED AT END OF LINE. SEE STANDARD DETAIL W-7.
- ⑤ IF A FIRE HYDRANT IS REQUIRED BY FIRE DEPARTMENT OR FIRE MARSHALL, IT SHALL BE LOCATED PRIOR TO THE LAST JOINT OF PIPE.
- ⑥ THRUST COLLAR SHALL BE AS SHOWN ON STANDARD DETAIL W-2A.

CITY OF SALISBURY, N.C. STANDARD DETAIL

DATE: JULY 19, 2022

WATER SYSTEMS

NOT TO SCALE

END OF LINE FOR FUTURE EXTENSION

STANDARD

W-6A