


PROVIDE RETAINER GLAND FOR EACH MECHANICAL JOINT FITTING (TEE, VALVE, BEND)

① RETAINER GLAND (MEGA-LUGS OR GRIP RINGS ONLY) FOR DUCTILE IRON PIPE

② SEE CURRENT APPROVED PRODUCT MANUFACTURERS SHEET FOR APPROVED TYPES (APPENDIX "A")



CITY OF SALISBURY, N.C.      STANDARD DETAIL	DATE:      OCTOBER 17, 2006 AMENDED:    MAY 19, 2009
WATER SYSTEMS FIRE HYDRANT	NOT TO SCALE
	STANDARD    W-3