



PROVIDE RETAINER GLAND FOR EACH MECHANICAL JOINT FITTING (TEE, VALVE, BEND)

- ① RETAINER GLAND (MEGA-LUGS OR GRIP RINGS ONLY) FOR DUCTILE IRON PIPE
- ② SEE CURRENT APPROVED PRODUCT MANUFACTURERS SHEET FOR APPROVED TYPES (APPENDIX "A")

FIRE HYDRANT WITH 5" STORZ CONNECTION IS REQUIRED WITHIN THE ZONING DISTRICT OF THE TOWN OF CHINA GROVE.

CITY OF SALISBURY, N.C. STANDARD DETAIL	DATE: JULY 19, 2022
TOWN OF CHINA GROVE FIRE HYDRANT WITH STORZ CONNECTION	NOT TO SCALE
	STANDARD W-3A