



PROVIDE RETAINER GLAND FOR EACH MECHANICAL JOINT FITTING (TEE, VALVE, BEND)

- ① RETAINER GLAND (MEGA-LUGS OR GRIP RINGS ONLY) FOR DUCTILE IRON PIPE
- ② SEE CURRENT APPROVED PRODUCT MANUFACTURERS SHEET FOR APPROVED TYPES (APPENDIX "A")

CITY OF SALISBURY, N.C. STANDARD DETAIL	DATE: OCTOBER 17, 2006 AMENDED: MAY 19, 2009
WATER SYSTEMS FIRE HYDRANT	NOT TO SCALE
	STANDARD W-3