



NOTES:

- ① HOIST SHALL BE LOCATED AS TO ALLOW EASY ACCESS & REMOVAL OF MOTORS & TRASH BASKET
- ② INLET PIPE & OUTLET PIPE SHALL BE LOCATED ON OPPOSITE SIDES (AT 180 DEGREES)

GROUT BOTTOM PER MANUFACTURER'S RECOMMENDATIONS

PRECAST CONCRETE MANHOLE - 5' MINIMUM DIAMETER

CITY OF SALISBURY, N.C. STANDARD DETAIL

DATE: OCTOBER 17, 2006

SEWER STANDARDS
LIFT STATION

NOT TO SCALE

STANDARD SS-9