



- ① RETAINER GLAND (MEGA-LUGS OR GRIP RINGS ONLY) FOR DUCTILE IRON PIPE. PROVIDE RETAINER GLAND FOR EACH MECHANICAL JOINT FITTING (TEE, VALVE, BEND)
- ② M.J. PLUG WITH THREADED HOLE FOR 2" BLOW-OFF PIPE OR M.J. REDUCER FOR BLOW-OFFS LARGER THAN 2".
- ③ IF REQUIRED BY FIRE MARSHALL OR FIRE DEPARTMENT.
- ④ BLOW-OFF REQUIRED AT END OF LINE. SEE STANDARD DETAIL W-7.

CITY OF SALISBURY, N.C. STANDARD DETAIL

DATE: JANUARY 1, 1991  
 REVISED: APRIL 19, 2011

WATER SYSTEMS  
 DEAD END LINES

NOT TO SCALE

STANDARD W-6