



NOTES:

1. TAPPING SADDLE - SEE CURRENT APPROVED PRODUCT MANUFACTURERS SHEET FOR APPROVED TYPES (APPENDIX A)
2. 1" CORPORATION STOP INLET AWWA THREAD OUTLET CTPJ (SEE APPENDIX A)
3. 1" MIP x 1" CTPJ
4. 1" BRASS TEE, FIP
5. DOMESTIC BRANCH:
1"x 3/4" BUSHING, 3/4" MIP x 3/4" CTS CURBSTOP W/PADLOCK WINGS & PLUG
6. STUB-OUT:
1" MIP x 1" CTS CURBSTOP W/PADLOCK WINGS & PLUG
7. COVER TEE AND CURBSTOPS WITH 6" OF WASHED STONE

CITY OF SALISBURY, N.C. STANDARD DETAIL	DATE: OCTOBER 17, 2006 AMENDED: MAY 19, 2009
WATER SYSTEM 1" SERVICE LINE FOR DOMESTIC 3/4" & 1" SERVICES	NOT TO SCALE
	STANDARD W-12